

14th District Agricultural Association / Santa Cruz County Fairgrounds

PUBLIC NOTICE RE: LEAD IN DRINKING WATER 6-16-22

En este aviso hay información muy importante de su agua potable y también va adjunto en español.

(A) INTRODUCTION. The California State Water Resources Control Board, Division of Drinking Water, the United States Environmental Protection Agency (EPA) and Santa Cruz County Fairgrounds are concerned about potential lead in your drinking water. A drinking water sample taken from this facility had lead levels above the EPA action level of 15 parts per billion (ppb), or 0.015 milligrams of lead per liter of water (mg/L). Under Federal law we are required to have a program in place to minimize lead in your drinking water. This program includes corrosion control treatment, source water treatment, and public education. We are also required to replace the portion of each lead service line that we own if the line contributes lead concentrations of more than 15 ppb after we have completed the comprehensive treatment program. If you have any questions about how we are carrying out the requirements of the lead regulation please give us a call at (831)-724-5671. This letter explains the simple steps you can take to protect yourself by reducing your exposure to lead in drinking water.

(B) HEALTH EFFECTS OF LEAD. Lead is found throughout the environment in lead-based paint, air, soil, household dust, food, certain types of pottery porcelain and pewter, and water. Lead can pose a significant risk to your health if too much of it enters your body. Lead builds up in the body over many years and can cause damage to the brain, red blood cells and kidneys. The greatest risk is to young children and pregnant women. Amounts of lead that won't hurt adults can slow down normal mental and physical development of growing bodies. In addition, a child at play often comes into contact with sources of lead contamination - like dirt and dust - that rarely affect an adult. It is important to wash children's hands and toys often, and to try to make sure they only put food in their mouths.

LEAD IN DRINKING WATER

1. Lead in drinking water, although rarely the sole cause of lead poisoning, can significantly increase a person's total lead exposure, particularly the exposure of infants who drink baby formulas and concentrated juices that are mixed with water. The EPA estimates that drinking water can make up 20 percent or more of a person's total exposure to lead.
2. Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing. These materials include lead-based solder used to

join copper pipe, brass and chrome-plated brass faucets, and in some cases, pipes made of lead that connect houses and buildings to water mains (service lines). In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials to 8.0%.

3. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, can contain fairly high levels of lead.

(D) STEPS YOU CAN TAKE. Steps you can take to reduce exposure to lead in drinking water include:

1. Let the water run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. The longer water resides in plumbing the more lead it may contain. Flushing the tap means running the cold water faucet for about 15-30 seconds. Although toilet flushing or showering flushes water through a portion of the plumbing system, you still need to flush the water in each faucet before using it for drinking or cooking. Flushing tap water is a simple and inexpensive measure you can take to protect your health. It usually uses less than one gallon of water.

2. Do not cook with, or drink water from the hot water tap. Hot water can dissolve more lead more quickly than cold water. If you need hot water, draw water from the cold tap and then heat it.

3. The steps described above will reduce the lead concentrations in your drinking water. However, if you are still concerned, you may wish to use bottled water for drinking and cooking.

4. You can consult a variety of sources for additional information. Your family doctor or pediatrician can perform a blood test for lead and provide you with information about the health effects of lead. Staff at Santa Cruz County Fairgrounds (831-724-5671) can provide you with information about your facility's water supply. The State Water Resources Control Board, Division of Drinking Water, Monterey District at (831) 655-6939 or dwpdist05@waterboards.ca.gov can provide you with information about the health effects of lead."

The 14th DAA has a lead in drinking water sampling program where we sample water from 5 sources within our Fairgrounds system in September of each year.

In September of 2021 samples were taken from the following locations:

Daycare Center, Concessions, Harvest Building, Crosetti Building, and Main Office.

The sample from the Harvest Building exceeded the federal drinking water standard for lead which is .015 MG/L. Re-sampling was conducted on October 5, 2021 where 4 samples from four different locations in the Harvest Building all tested below .015 MG/L.

Three of the four samples were 0.00 MG/L including the location that produced a higher than .015 MG/L result in September. The fourth sample produced a result of .0078 MG/l which is approximately half of the federal drinking water allowable standard. However, since these samples were submitted after the September 30 deadline the samples are not counted towards compliance.

(1) Why should everyone want to know the facts about lead and drinking water? Because unhealthy amounts of lead can enter drinking water through the plumbing in your home. You can contact the for information on testing and on simple ways to reduce your exposure to lead in drinking water.

To have your water tested for lead, or to get more information about this public health concern, please call (831)-724-5671